



NOTES:

1. MAXIMUM WIDTH OF TRENCH AT TOP OF PIPE
  - \* 30" FOR PIPE UP TO AND INCLUDING 12" NOMINAL DIAMETER.
  - \* O.D. PLUS 16" FOR PIPE LARGER THAN 12" NOMINAL DIAMETER.
2. EXCAVATIONS OVER 4' DEEP SHALL COMPLY WITH THE SAFETY STANDARD DESCRIBED IN CHAPTER 296-155-PART N OF THE WAC.
3. SEE "BACKFILLING TRENCHES" IN CHAPTER D8 OF THE ENGINEERING STANDARDS FOR ADDITIONAL CONSTRUCTION REQUIREMENTS.



City of  
Bellevue

STORM AND SURFACE  
WATER UTILITY

TITLE

TYPICAL TRENCH DETAIL

JANUARY 2012

NO SCALE

NO. D-25